

TREE PROTECTION PLAN

12.7.20

Forston St

Project Manager - Rick Holley

***All root pruning shall be done to a maximum depth of 6"**

DBH = diameter (in.) at breast height (4.5 ft above ground), ms = multi stem

Location: F = front, S = side, R = rear, I = island, P = private, O = opposite, M = median

Recommendation: F = Fencing required, s/w = sidewalk, elev = elevation pruning

DW = dead wood removal, d/w = driveway, cli = clear light, csi = clear sign, cpt = clear private tree, ch = clear house

Note: refer to **Tree Protection Requirements For The Department Of Transportation** for Standard Tree Protection Measures

Note: Inspection of worksite tree protection measures required by Certified Arborist with the county prior to construction activities

Note: ROW not to be utilized for staging area unless otherwise permitted by Certified Arborist

Note: three (3) trees required per tree removal (\$250.00 per tree)

Note: Tree replacement fee to be paid prior to scheduled construction

Page 1 of 1

ADDRESS	SPECIES	DBH	LOCATION	RECOMMENDATIONS
8401 Barron St	Cedar	19	1S-P	Elevate 8' over proposed sidewalk, Root prune up to edge of proposed s/w
8401 Barron St	Mulberry	14 ms	2S-P	Elevate 8' over proposed sidewalk, Root prune up to edge of proposed s/w
8401 Barron St	Holly	12 ms	3S-P	Elevate 8' over proposed sidewalk, Root prune up to edge of proposed s/w
704	Redbud	7	1F-P	F
706	Hedge Maple	7	1F	REMOVE: Proposed construction would compromise health/structural stability of tree
706	Cherry	8	1F-P	F
708	Purpleleaf Plum	10	1F-P	F, Elevate 8' over proposed s/w,
710	Cherry	4	1F	F
710	Cherry	5	1F-P	F
716	Japanese Maple	13	1F-P	F, Root prune up to edge of proposed s/w
718	Red Maple	13	1F-P	Root prune up to edge of proposed s/w
806	Black Cherry	12	1F-P	F, Root prune up to edge of proposed s/w
808	Red Maple	23	1F-P	F, Root prune up to edge of proposed s/w
810	Silver Maple	29	1F-P	F, Root prune up to edge of proposed s/w
				Note: Per Montgomery County Roadside Tree Protection Law, allocation of \$750.00 into the Street Tree Replacement Fund is required.
				1. Hand prune roots where noted above.
				2. Any roots 2" diameter or larger exposed by air excavation or by hand pruning activities, that require removal due to sidewalk construction, shall be inspected by ISA certified arborist with the Tree Maintenance Section, Montgomery County, prior to removal.
				3. An approved contractor certified in the State of Maryland for air excavation will be required to conduct all excavation where "Air Excavation required" is noted above.
				4. Arborist (Tree Maintenance Section, Division of Highway Services) shall be notified by Project Manager of root pruning and air excavation schedule prior to scheduled work.
				5. Root pruning shall be to the depth of excavation (no more than 6" depth)
				6. Excavation for proposed sidewalk shall be no more than 6"