



**DPS**

Montgomery County  
Department of Permitting Services



2425 Reedie Drive, 7th Floor  
Wheaton, MD 20902  
240-777-0311  
montgomerycountymd.gov/dps

### Residential Sheds Building Inspections

Inspection Sequence Type	Code	Prior to Inspection Request		Performed by		Inspection approval required prior to
		Work to be Completed	Approved Inspections	DPS	Others	
Final	251	1. Shed is to be completed and must be anchored to resist wind loads. Anchorage shall be installed to resist a minimum 15 pounds per square foot lateral load as required code or by using other hardware installed in accordance with the manufacturers specifications. Shed placement shall comply with the approved plot plan for size and location		Yes		<ul style="list-style-type: none"> <li>Using building or structure</li> </ul>