



MONTGOMERY COUNTY EXECUTIVE ORDER

Offices of the County Executive • 101 Monroe Street • Rockville, Maryland 20850

Subject Street Acceptance	Executive Order No. 214-13	Subject Suffix SA
Originating Department Department of Permitting Services	Department Number 01-13	Effective Date 11/19/13

Re: Acceptance of Roads for Maintenance MCDPS Permits Nos.
240838, 256585, 259157, 259292,
264274, 266685, 266686, 268915.

This is to certify that construction of the following named streets has been completed in accordance with all applicable provisions of the Montgomery County Road Construction Code as specified in the above-captioned permit. The materials used in the construction of these streets were tested and found to be in compliance with County Specifications.

Clarksburg Village
Permit No.: 240838
Date of Final Inspection: October 12, 2012
Total Distance: 825 feet / 0.16 miles
Total Lane Miles: 0.34
Total Bond Amount: \$156,200.00

Clarksburg Village Investment Inc
1355 Beverly Road, Suite 240
Mc Lean, Virginia 22101-3649

FOREMAN BOULEVARD: A modified primary residential road with a right-of-way 80 feet wide starting at Station 11+06.11, 28 feet northeast of Timber Creek Lane to Station 19+45, 867 feet northeast of Timber Creek Lane. A distance of 839 feet, 26 feet wide, sidewalks right side only, bikeway left side only, curb and gutters, storm drainage, with a 5-inch asphaltic concrete base course, an 1½-inch asphaltic concrete intermediate course, and an 1½-inch asphaltic concrete surface course.

Crabbs Branch Way - Extension
Permit No.: 256585
Date of Final Inspection: February 8, 2012
Total Distance: 340 feet / 0.06 miles
Total Lane Miles: 0.27
Total Bond Amount: \$318,000.00

S. G. Homes Associates L.P.
4800 Hampden Lane, Suite 300
Bethesda, Maryland 20814

CRABBS BRANCH WAY: A modified business district roadway with a right-of-way varying from 80 feet to 86 feet wide starting at Station 9+01, 901 feet northwest of Shady Grove Road to Interstate I-370 Highway Right-of-Way (Station 10+93.02). A distance of 192 feet, 50 feet wide, bikeways, curb and gutters, storm drainage, with an 8-inch dense graded aggregate base course, a 7-inch asphaltic concrete base course, an 1½-inch asphaltic concrete intermediate course, and an 1½-inch asphaltic concrete surface course.

CRABBS BRANCH WAY: A business road with a right-of-way varying from 86 feet to 106 feet wide starting from the State of Maryland Inter-County Connector Right-of-Way (Station 15+39.29), to and ending in a temporary turnaround (Station 16+87). A distance of 148 feet, 50 feet wide, bikeways, curb and gutters, storm drainage, with an 8-inch dense graded aggregate base course, a 7-inch asphaltic concrete base course, an 1½-inch asphaltic concrete intermediate course, and an 1½-inch asphaltic concrete surface course.



MONTGOMERY COUNTY EXECUTIVE ORDER

Offices of the County Executive • 101 Monroe Street • Rockville, Maryland 20850

Subject Street Acceptance	Executive Order No. 214-13	Subject Suffix SA
Originating Department Department of Permitting Services	Department Number 01-13	Effective Date 11/19/13

Greenway Village
Permit No.: 259157
Date of Final Inspection: December 7, 2012
Total Distance: 821 feet/ 0.16 miles
Total Lane Miles: 0.52
Total Bond Amount: \$165,500.00

NEW CUT ROAD: A commercial road with a right-of-way 70 feet wide from Little Seneca Parkway (Station 10+07.26) to Station 18+28.73, 159 feet southwest of Arora Hills Drive, including the intersection of Arora Hills Drive (Station 16+69.80). A distance of 821 feet, 40 feet wide, bikeway left side only, sidewalks right side only, curb and gutters, storm drainage, with an 8-inch dense graded aggregate base course, a 7-inch asphaltic concrete base course, an 1½-inch asphaltic concrete intermediate course, and an 1½-inch asphaltic concrete surface course.

Clarksburg Skylark, L.L.C.
7200 Wisconsin Avenue, Suite 100
Bethesda, Maryland 20814

Greenway Village
Permit No.: 259292
Date of Final Inspection: December 7, 2012
Total Distance: 690 feet / 0.13 miles
Total Lane Miles: 0.39
Total Bond Amount: \$77,000.00

Clarksburg Skylark, L.L.C.
7200 Wisconsin Avenue, Suite 100
Bethesda, Maryland 20814

ARORA HILLS DRIVE: A modified secondary residential road with a right-of-way 60 feet wide from New Cut Road (Station 0+00) to Little Seneca Parkway (Station 6+90.44). A distance of 690 feet, 36 feet wide, sidewalks, curb and gutters, storm drainage, with a 3-inch asphaltic concrete base course, an 1½-inch asphaltic concrete intermediate course, and an 1½-inch asphaltic concrete surface course.

Greenway Village
Permit No.: 264271
Date of Final Inspection: September 24, 2012
Total Distance: 961 feet / 0.18 miles
Total Lane Miles: 0.44
Total Bond Amount: \$167,800.00

Clarksburg Skylark, L.L.C.
7200 Wisconsin Avenue, Suite 100
Bethesda, Maryland 20814

MEADOW MIST ROAD: A modified secondary residential road with a right-of-way 60 feet wide from Skylark Road (Station 20+00) to and including the intersection of Tulip Tree Drive (Station 23+01.51). A distance of 302 feet, 36 feet wide, sidewalks, curb and gutters, storm drainage, with a 5-inch asphaltic concrete base course, an 1½-inch asphaltic concrete intermediate course, and an 1½-inch asphaltic concrete surface course.

TULIP STEM DRIVE: A tertiary residential road with a right-of-way 50 feet wide from Meadow Mist Road (Station 0+00) to Spicebush Drive (Station 6+58.85). A distance of 659 feet, 26 feet wide, sidewalks, curb and gutters, storm drainage, with a 3-inch asphaltic concrete base course, an 1½-inch asphaltic concrete intermediate course, and an 1½-inch asphaltic concrete surface course.



MONTGOMERY COUNTY EXECUTIVE ORDER

Offices of the County Executive • 101 Monroe Street • Rockville, Maryland 20850

Subject Street Acceptance	Executive Order No. 214-13	Subject Suffix SA
Originating Department Department of Permitting Services	Department Number 01-13	Effective Date 11/19/13

Greenway Village
Permit No.: 266685
Date of Final Inspection: December 7, 2012
Total Distance: 578 feet / 0.11miles
Total Lane Miles: 0.33
Total Bond Amount: \$91,100.00

Clarksburg Skylark, L.L.C.
7200 Wisconsin Ave, Suite 1000
Bethesda, Maryland 20814

MEADOW MIST ROAD: A modified secondary residential road with a right-of-way 60 feet wide from Tulip Tree Road (Station 23+01.51) to Little Seneca Parkway (Station 28+79.51), including the intersection of Steeplebush Drive (Station 25+93.51). A distance of 578 feet, 36 feet wide, sidewalks, curb and gutters, storm drainage, with a 3-inch asphaltic concrete base course, an 1½-inch asphaltic concrete intermediate course, and an 1½-inch asphaltic concrete surface course.

Greenway Village
Permit No.: 266686
Date of Final Inspection: December 7, 2012
Total Distance: 989 feet / 0.19 miles
Total Lane Miles: 0.41
Total Bond Amount: \$163,500.00

Clarksburg Skylark, L.L.C.
7200 Wisconsin Avenue, Suite 100
Bethesda, Maryland 20814

STEEPLEBUSH DRIVE: A tertiary residential road with a right-of-way 50 feet wide from Meadow Mist Drive (Station 0+00) to Spicebush Drive (Station 7+02.60), including the intersection of Sweetspire Drive (Station 3+67). A distance of 703 feet, 26 feet wide, sidewalks, curb and gutters, storm drainage, with a 3-inch asphaltic concrete base course, an 1½-inch asphaltic concrete intermediate course, and an 1½-inch asphaltic concrete surface course.

SWEETSPIRE DRIVE: A tertiary residential road with a right-of-way 50 feet wide from Little Seneca Parkway (Station 0+00) to Steeplebush Drive (Station 2+860). A distance of 286 feet, 26 feet wide, sidewalks, curb and gutters, storm drainage, with a 3-inch asphaltic concrete base course, an 1½-inch asphaltic concrete intermediate course, and an 1½-inch asphaltic concrete surface course.

Clarksburg Village
Permit No.: 268915
Date of Final Inspection: October 25, 2012
Total Distance: 462 feet / 0.09 miles
Total Lane Miles: 0.19
Total Bond Amount: \$92,000.00

Clarksburg Village Investment Inc
1355 Beverly Road, Suite 240
Mc Lean, Virginia 22101-3649

SYCAMORE FARM DRIVE: A secondary residential road with a right-of-way 60 feet wide starting at Station 29+12.29, 43 feet southeast of Cypress Spring Road to Snowden Farm Parkway (Station 33+73.97 - A-305). A distance of 462 feet, 26 feet wide, sidewalks, curb and gutters, storm drainage, with a 3-inch asphaltic concrete base course, an 1½-inch asphaltic concrete intermediate course, and an 1½-inch asphaltic concrete surface course.



MONTGOMERY COUNTY EXECUTIVE ORDER

Offices of the County Executive • 101 Monroe Street • Rockville, Maryland 20850

Subject Street Acceptance	Executive Order No. 214-13	Subject Suffix SA
Originating Department Department of Permitting Services	Department Number 01-13	Effective Date 11/19/13

SUMMARY OF THIS EXECUTIVE ORDER

Number of Permits: 8
 Number of Subdivisions: 3
 Distance of Streets Accepted - Feet: 5,666
 Distance of Streets Accepted - Miles: 1.07
 Distance of Streets Accepted - Lane-Miles: 2.89

All work and submissions required for acceptance of the foregoing streets has been completed and acceptance is recommended.

Nov. 12, 2013
Date

By: Christina T. Contino
Manager, Department of Permitting Services
Division of Land Development
Right-of-Way Inspections

It is recommended that Montgomery County, Maryland, accept the roads described above for maintenance:

November 13, 2013
Date

Diane R. Schwartz Jones
Director, Department of Permitting Services

Said roads are hereby accepted for maintenance:

11/19/13
Date

Thomas Stunt
Assistant Chief Administrative Officer