

DIVISION OF FIRE CODE ENFORCEMENT

**ADMINISTRATIVE EXCEPTION 94-1
AMENDED 10/16/96**

CODE REFERENCE: Montgomery County Fire Safety Code Section 22-45
"above Ground Tank Storage of Flammable Liquids."

BACKGROUND: This code section prohibits the use of above ground storage tanks for class I and class II flammable and combustible liquids, except when being used on farms, on temporary basis not to exceed 6 months and existing tanks approved prior to 4/28/59.

EXCEPTION: To allow the use of above ground storage tanks for class I and class II flammable and combustible liquids.

COMPENSATORY ACTION: To provide listed Above Ground Vaulted Tanks in accordance with the U.L. Standard 2085 or equivalent. Tank must be marked per NFPA 704 on all four sides.

PREPARED BY: District Chief A. H. Isaacs

DATE 10/16/96

FIRE MARSHAL J. R. Dethlefs