



Q1 2022 DA FIG Report for GenOn Holdings LLC., Dickerson Facilities

Coal Plant Decommissioning/Caretaking (Dickerson Infra-Development, LLC.)

- Safety concerns for the period – **None**
- Environmental concerns for the period – **None**
- Pepco 230Kv bus tie project in the “D” Switchyard underway (GenOn separation)
- NPDES permit remains in place currently. Awaiting input from MDE on permit termination.
- No salvage operations currently at the Facility
- Working with Dominion Power on site Access needs for First Energy Transmission line project
- Marketing of Infra property with Real Estate broker underway

Combustion Turbine Site (Dickerson Power, LLC.)

- Safety concerns for the period – **None**
- Environmental concerns for the period – **None**
- No operational issues to report since the last review
 - 220 Starts in 2021 / 1630 Service Hours in 2021
 - 6 starts thru Feb2022 / 42 Service Hours thru Feb2022
- Summer Readiness outage planning underway

Westland Ash Landfill (Maryland Ash Management, LLC.)

- Safety concerns for the period – **None**
- Environmental concerns for the period – **None**
- No operational issues during the period
 - Processed and discharged 4,365,300 gal thru WWTP in 2021
 - Processed and discharged 414,600 gal thru WWTP thru Feb2022
- Ash mining activities were intermittent during the period
 - 12,386 tons of Fly Ash removed in Feb22
 - 14,071 tons of Fly Ash removed in 2022
 - 167,204.96 tons of Fly Ash removed in 2021
 - 318,559 removed since project start (does not include 2022)

Mike Bennett

Plant Manager - Chalk Point/Dickerson Stations

Lanyard Power, LLC

C - 240.372.3049

O - 301.601.6522

David.Bennett@GenOn.com