



APTIM

200 Horizon Center

Trenton, NJ 08691

Tel: +1 609.584.8900

Fax: +1 609.588.6300

www.aptim.com

March 27, 2019

Ms. Katherine McIlroy
Project Analyst/Manager
Northeast Maryland Waste Disposal Authority
100 South Charles Street
Tower II – Suite 402
Baltimore, MD 21201

Oaks Landfill
Laytonsville, Maryland
2018 Annual Emissions Certification Report

Dear Ms. McIlroy:

Aptim Environmental and Infrastructure, LLC (APTIM) is submitting one copy of the 2018 Annual Emissions Certification Report for the Oaks Landfill Gas-to-Energy Facility in Rockville, Maryland, in accordance with Permit to Operate (PTO) 031-1723. There were no changes to the air toxics assessment for the 2018 calendar year, such that an updated analysis was not required. Two copies of the report must be submitted to the MDE offices by April 1, 2019, addressed to:

Maryland Department of the Environment
Air and Radiation Management Administration
1800 Washington Boulevard Suite 715
Baltimore, MD 21230-1720
Attn: Laramie Daniel, Compliance Program

The Responsible Official for the site must complete and submit the Certification of Truth, Accuracy, and Completeness with the report. In addition, a statement should be included certifying that the site is in compliance with the air toxic regulations, and there have been no changes in the air toxics assessment during the 2018 calendar year.

Should you have any questions and/or comments, please do not hesitate to contact the undersigned at 609-588-6398.

Respectfully Submitted,

Aptim Environmental & Infrastructure, LLC

John V. Esmet
Project Manager

Attachment

MARYLAND DEPARTMENT OF THE ENVIRONMENT
 1800 Washington Boulevard, Suite 715 • Baltimore Maryland 21230-1720
 410-537-3000 • 1-800-633-6101 • <http://www.mde.state.md.us>
 Air and Radiation Management Administration
 Air Quality Compliance Program
 410-537-3220

FORM 1:

GENERAL FACILITY INFORMATION
EMISSIONS CERTIFICATION REPORT

Calendar Year: 2018

				Do Not Write in This Space
A. FACILITY IDENTIFICATION				Date Received Regional
Facility Name <i>Oaks Landfill Gas To Energy</i>				
Address <i>6001 Olney-Laytonsville Road</i>				Date Received State
City <i>Laytonsville</i> County <i>Montgomery</i> Zip Code <i>20882</i>				AIRS Code
B. Briefly describe the major function of the facility <i>Landfill gas to energy</i>				FINDS Code
				SIC Code
				Facility Number:
				TEMPO ID:
C. SEASONAL PRODUCTION (%), if applicable)				Reviewed by:
<u>Winter</u> (Dec.-Feb.) <u>25%</u>	<u>Spring</u> (Mar - May) <u>25%</u>	<u>Summer</u> (Jun - Aug) <u>25%</u>	<u>Fall</u> (Sept - Nov) <u>25%</u>	Name _____ Date _____

D. Explain any increases or decreases in emissions from the previous calendar year for each registration at this facility.

Small variation due to changes in operation and gas collection

E. CONTROL DEVICE INFORMATION (for NOx and VOC sources only)		
Control Device	Capture Efficiency	Removal Efficiency
<i>Landfill Gas Collection Flare System</i>	N/A	98.0% (Permit)
<i>1,600 kW Caterpillar Engine</i>	N/A	97.2% (AP-42)
<i>848 kW GE Jenbacher Engine</i>	N/A	97.2% (AP-42)

I am familiar with the facility and the installations and sources for which this report is submitted. I have personally examined the information in this report, which consists of 18 pages (including attachments), and certify that the information is correct to the best of my knowledge.

CHRISTOPHER SKAGGS


EXECUTIVE DIRECTOR

3/27/19

Name (Print/Type)

Title

Date



Signature

410-333-2730

Telephone

FORM 2:

CRITERIA AIR POLLUTANTS **EMISSIONS CERTIFICATION REPORT**

Calendar Year:

Facility Name: _____

Facility ID: _____

Pollutant: _____

S - Stack Emissions

F - Fugitive Emissions

Daily emissions (lbs/day) are lbs/operating day of the source

TOSD: Typical Ozone Season Day means a typical day of that period of the year during which conditions for photochemical conditions are most favorable, which is generally during sustained periods of direct sunlight and warm temperatures (April-September). This section needs to be completed only for VOC and NOx sources.

Fuel: Include emissions for each fuel used. If more than one fuel is used, calculate and list emissions separately for each fuel.

Emission Estimation Method

- - A1-U.S. EPA Reference Method
 - A2-Other Particulate Sampling Train
 - A3-Liquid Absorption Technique
 - A4-Solid Absorption Technique
 - A5-Freezing Out Technique
 - A9-Other, Specify

- C1-User calculated based on source test or other measurement
 - C2-User calculated based on material balance using engineering knowledge of the process
 - C3-User calculated based on AP-42
 - C4-User calculated by best guess/engineering Judgment

- C5-User calculated based on a State or local agency emission factor
 - C6-New construction, not operational
 - C7-Source closed, operation ceased
 - C8-Computer calculated based on standard

FORM 2:

CRITERIA AIR POLLUTANTS **EMISSIONS CERTIFICATION REPORT**

Calendar Year:

Facility Name: _____

Facility ID: _____

Pollutant: _____

S - Stack Emissions

F - Fugitive Emissions

Daily emissions (lbs/day) are lbs/operating day of the source

TOSD: Typical Ozone Season Day means a typical day of that period of the year during which conditions for photochemical conditions are most favorable, which is generally during sustained periods of direct sunlight and warm temperatures (April-September). This section needs to be completed only for VOC and NOx sources.

Fuel: Include emissions for each fuel used. If more than one fuel is used, calculate and list emissions separately for each fuel.

Emission Estimation Method

- - A1-U.S. EPA Reference Method
 - A2-Other Particulate Sampling Train
 - A3-Liquid Absorption Technique
 - A4-Solid Absorption Technique
 - A5-Freezing Out Technique
 - A9-Other, Specify

- C1-User calculated based on source test or other measurement
 - C2-User calculated based on material balance using engineering knowledge of the process
 - C3-User calculated based on AP-42
 - C4-User calculated by best guess/engineering Judgment

- C5-User calculated based on a State or local agency emission factor
 - C6-New construction, not operational
 - C7-Source closed, operation ceased
 - C8-Computer calculated based on standard

FORM 2:

CRITERIA AIR POLLUTANTS **EMISSIONS CERTIFICATION REPORT**

Calendar Year:

Facility Name: _____

Facility ID: _____

Pollutant: _____

S - Stack Emissions

F - Fugitive Emissions

Daily emissions (lbs/day) are lbs/operating day of the source

TOSD: Typical Ozone Season Day means a typical day of that period of the year during which conditions for photochemical conditions are most favorable, which is generally during sustained periods of direct sunlight and warm temperatures (April-September). This section needs to be completed only for VOC and NOx sources.

Fuel: Include emissions for each fuel used. If more than one fuel is used, calculate and list emissions separately for each fuel.

Emission Estimation Method

- - A1-U.S. EPA Reference Method
 - A2-Other Particulate Sampling Train
 - A3-Liquid Absorption Technique
 - A4-Solid Absorption Technique
 - A5-Freezing Out Technique
 - A9-Other, Specify

- C1-User calculated based on source test or other measurement
 - C2-User calculated based on material balance using engineering knowledge of the process
 - C3-User calculated based on AP-42
 - C4-User calculated by best guess/engineering Judgment

- C5-User calculated based on a State or local agency emission factor
 - C6-New construction, not operational
 - C7-Source closed, operation ceased
 - C8-Computer calculated based on standard

FORM 2:

CRITERIA AIR POLLUTANTS **EMISSIONS CERTIFICATION REPORT**

Calendar Year:

Facility Name: _____

Facility ID: _____

Pollutant: _____

S - Stack Emissions

F - Fugitive Emissions

Daily emissions (lbs/day) are lbs/operating day of the source

TOSD: Typical Ozone Season Day means a typical day of that period of the year during which conditions for photochemical conditions are most favorable, which is generally during sustained periods of direct sunlight and warm temperatures (April-September). This section needs to be completed only for VOC and NOx sources.

Fuel: Include emissions for each fuel used. If more than one fuel is used, calculate and list emissions separately for each fuel.

Emission Estimation Method

- - A1-U.S. EPA Reference Method
 - A2-Other Particulate Sampling Train
 - A3-Liquid Absorption Technique
 - A4-Solid Absorption Technique
 - A5-Freezing Out Technique
 - A9-Other, Specify

- C1-User calculated based on source test or other measurement
 - C2-User calculated based on material balance using engineering knowledge of the process
 - C3-User calculated based on AP-42
 - C4-User calculated by best guess/engineering Judgment

- C5-User calculated based on a State or local agency emission factor
 - C6-New construction, not operational
 - C7-Source closed, operation ceased
 - C8-Computer calculated based on standard

FORM 3: PM**EMISSIONS CERTIFICATION REPORT****Particulate Matter**

Calendar Year: _____

Facility Name: _____ Facility ID: _____ Pollutant: PM

Equipment Description/ Registration No.	SCC Number	Fuel	PM – Filterable		PM 10 – Filterable		PM 2.5 – Filterable		PM Condensable		Operation	Emissions Methods
			Tons/yr	Lbs/day	Tons/yr	Lbs/day	Tons/yr	Lbs/day	Tons/yr	Lbs/day		
		S										
		F										
		S										
		F										
		S										
		F										
		S										
		F										
		S										
		F										
		S										
		F										
		S										
		F										
		S										
		F										
		S										
		F										
		S										
		F										
		S										
		F										
		S										
		F										
		S										
		F										
Total												

S - Stack Emissions

F - Fugitive Emissions

Daily emissions (lbs/day) are lbs/operating day of the source

Fuel: Include emissions for each fuel used. If more than one fuel is used, calculate and list emissions separately for each fuel.

Emission Estimation Method

- A1-U.S. EPA Reference Method
- A2-Other Particulate Sampling Train
- A3-Liquid Absorption Technique
- A4-Solid Absorption Technique
- A5-Freezing Out Technique
- A9-Other, Specify

- C1-User calculated based on source test or other measurement
- C2-User calculated based on material balance using engineering knowledge of the process
- C3-User calculated based on AP-42
- C4-User calculated by best guess/engineering Judgment

- C5-User calculated based on a State or local agency emission factor
- C6-New construction, not operational
- C7-Source closed, operation ceased
- C8-Computer calculated based on standard

FORM 4:

TOXIC AIR POLLUTANTS

Calendar Year: _____

EMISSIONS CERTIFICATION REPORT

Facility Name: _____ **Facility ID:** _____ **Pollutant:** _____*

* Please attach all calculations.

* See Attachment 1 for the minimum reporting values.

****Control Device**

S = Scrubber
B = Baghouse
ESP = Electrostatic Precipitator
A = Afterburner
C = Condenser
AD = Adsorbtion
O = Other

¹Emissions must be broken down by equipment registration number (ex. 9-0076, 9-0077)

FORM 5:**BILLABLE TOXIC AIR POLLUTANTS**

Calendar Year: _____

Emissions Certification Report

Facility Name: _____ Facility ID#: _____

Chemical Name	CAS Number		Actual Emissions				Estimation Method
			Tons/year	Lbs/day	Lbs/hr		
carbon disulfide	75-15-0	S					
		F					
carbonyl sulfide	463-58-1	S					
		F					
chlorine	7782-50-5	S					
		F					
cyanide compounds	57-12-5	S					
		F					
hydrochloric acid	7647-01-0	S					
		F					
hydrogen fluoride	7664-39-3	S					
		F					
methyl chloroform	71-55-6	S					
		F					
methylene chloride	75-09-2	S					
		F					
perchloroethylene	127-18-4	S					
		F					
phosphine	7803-51-2	S					
		F					
titanium tetrachloride	7550-45-0	S					
		F					
TOTALS							

S-Stack Emissions

F-Fugitive Emissions

Daily emissions (lbs/day) are lbs/operating day of the source

Emission Estimation Method

- A1-U.S. EPA Reference Method
- A2-Other Particulate Sampling Train
- A3-Liquid Absorption Technique
- A4-Solid Absorption Technique
- A5-Freezing Out Technique
- A9-Other, Specify

- C1-User calculated based on source test or other measurement
- C2-User calculated based on material balance using engineering knowledge of the process
- C3-User calculated based on AP-42
- C4-User calculated by engineering judgment
- C5-User calculated based on a State or local agency factor
- C6-New construction, not operational
- C7-Source closed, operation ceased
- C8-Computer calculated based on standards

This form is to include only the chemicals identified.

PLEASE NOTE: Be sure to attach all data and calculations necessary to support the emissions figures shown above.

FORM 6: Greenhouse Gases**GREENHOUSE GAS AIR POLLUTANTS**

Calendar Year: _____

EMISSIONS CERTIFICATION REPORT

Facility Name: _____ Facility ID: _____ Pollutant: _____ *

Equipment Description/ Registration Number ¹	Actual Emissions		
	Tons/yr	Lbs/day	Lbs/hr

TOTALS			

This form must be used to report
Greenhouse gas emissions:

- carbon dioxide (CO2)
- methane (CH4)
- nitrous oxide (N2O)
- hydrofluorocarbons (HFCs)
- perfluorocarbons (PFCs)
- sulfur hexafluoride (SF6)

* Use a separate form for each pollutant.

* Please attach all calculations.

¹Emissions must be broken down by equipment registration number (ex. 9-0076, 9-0077)

FORM 6: Greenhouse Gases**GREENHOUSE GAS AIR POLLUTANTS**

Calendar Year: _____

EMISSIONS CERTIFICATION REPORT

Facility Name: _____ Facility ID: _____ Pollutant: _____ *

Equipment Description/ Registration Number ¹	Actual Emissions		
	Tons/yr	Lbs/day	Lbs/hr

TOTALS			

This form must be used to report
Greenhouse gas emissions:

- carbon dioxide (CO2)
- methane (CH4)
- nitrous oxide (N2O)
- hydrofluorocarbons (HFCs)
- perfluorocarbons (PFCs)
- sulfur hexafluoride (SF6)

* Use a separate form for each pollutant.

* Please attach all calculations.

¹Emissions must be broken down by equipment registration number (ex. 9-0076, 9-0077)

FORM 6: Greenhouse Gases**GREENHOUSE GAS AIR POLLUTANTS**

Calendar Year: _____

EMISSIONS CERTIFICATION REPORT

Facility Name: _____ Facility ID: _____ Pollutant: _____ *

Equipment Description/ Registration Number ¹	Actual Emissions		
	Tons/yr	Lbs/day	Lbs/hr

TOTALS			

This form must be used to report
Greenhouse gas emissions:

- carbon dioxide (CO2)
- methane (CH4)
- nitrous oxide (N2O)
- hydrofluorocarbons (HFCs)
- perfluorocarbons (PFCs)
- sulfur hexafluoride (SF6)

* Use a separate form for each pollutant.

* Please attach all calculations.

¹Emissions must be broken down by equipment registration number (ex. 9-0076, 9-0077)

NorthEast Maryland Waste Disposal Authority - Oaks Landfill

Reporting Year:

2018

Denotes Input Data

OPERATING DATA

Month	Flare Operation		CAT Engine Operation		JEN Engine Operation	
	Hours	Days	Hours	Days	Hours	Days
Jan	6.4	0.26	661.0	27.54	717.0	29.88
Feb	0.3	0.01	656.0	27.33	666.0	27.75
Mar	23.6	0.98	660.0	27.50	710.0	29.58
Apr	0.5	0.02	597.0	24.88	716.0	29.83
May	387.7	16.15	375.0	15.63	711.0	29.63
Jun	91.3	3.80	475.0	19.79	557.0	23.21
Jul	256.3	10.68	701.0	29.21	710.0	29.58
Aug	4.9	0.20	671.0	27.96	732.0	30.50
Sep	7.2	0.30	696.0	29.00	702.0	29.25
Oct	8.0	0.33	730.0	30.42	739.0	30.79
Nov	212.6	8.86	432.0	18.00	715.0	29.79
Dec	3.5	0.15	726.0	30.25	739.0	30.79
TOTAL	1,002.16	41.76	7,380.00	307.50	8,414.00	350.58

LANDFILL GAS USAGE DATA

Month	LFG to Flare (MMscf)	Avg LFG Flare Flow Rate (cfm)	LFG to CAT Engine (MMscf)	Avg LFG CAT Engine Flow Rate (cfm)	LFG to JEN Engine (MMscf)	Avg LFG JEN Engine Flow Rate (cfm)	Total LFG (MMscf)	LFG Avg Methane Content (%)	LFG Avg Carbon Dioxide Content* (%)
Jan	0.18	477.69	28.92	729.08	14.90	346.25	43.99	46.00%	33.80%
Feb	0.01	384.62	28.23	717.18	14.54	363.91	42.78	46.10%	33.83%
Mar	0.67	474.47	28.43	717.83	14.64	343.75	43.74	41.32%	32.48%
Apr	0.02	586.42	27.95	780.32	14.40	335.17	42.37	40.70%	31.35%
May	7.99	343.50	26.91	1,196.21	13.87	325.02	48.77	39.80%	31.73%
Jun	2.88	526.40	24.26	851.05	12.50	373.88	39.63	38.80%	33.50%
Jul	4.40	286.03	32.06	762.31	16.52	387.73	52.98	41.30%	32.16%
Aug	0.14	477.16	31.57	784.26	16.27	370.35	47.98	42.40%	33.28%
Sep	0.26	590.95	30.52	730.80	15.72	373.26	46.50	42.30%	34.30%
Oct	0.27	564.58	26.93	614.95	13.88	312.93	41.08	43.40%	32.78%
Nov	3.05	239.06	34.81	1,342.92	17.93	417.99	55.79	44.90%	34.97%
Dec	0.09	401.32	35.70	819.55	18.39	414.76	54.18	45.20%	34.20%
TOTAL	19.95	-	356.29	-	183.54	-	559.78	-	-
AVERAGE	-	446.02	-	837.21	-	363.75	-	42.69%	33.20%

*CO2 readings derived from monthly GEM readings. For missing readings, the months prior and following a missing reading are averaged.

POWER OUTPUT FOR THE ENGINES

Month	1600 kW CAT Engine (BHP-hr)	848 kW GE Jenbacher Engine (BHP-hr)
Jan	1,219,428	705,661
Feb	1,218,494	635,058
Mar	1,133,488	660,575
Apr	988,387	673,557
May	619,767	668,231
Jun	798,042	514,140
Jul	1,125,159	620,640
Aug	1,084,849	655,160
Sep	1,140,112	658,364
Oct	1,190,267	692,161
Nov	742,631	682,268
Dec	1,297,584	745,547
TOTAL	12,558,208	7,911,362

ENGINE RATINGS (Operating Permit 031-1723, issued 9/28/2015)

Caterpillar Engine	2233 bhp
Jenbacher Engine	1175 bhp

NOx FACTORS - Compliance Emissions Test Report

Test Date: 5/30/2018

CAT Engine JEN Engine

NOx Emission Factor (g/BHP-hr):

0.28 0.73

DEVICE DESTRUCTION EFFICIENCIES FOR LFG CONSTITUENTS

Flare System	98.0%	Manufacturer design for NMOC; Permit 031-1723
Caterpillar Engine	97.2%	AP-42 Table 2.4-3 (10/08)
Jenbacher Engine	97.2%	AP-42 Table 2.4-3 (10/08)

LFG ANALYSIS DATA

Component	Concentration (ppmv)	
Total Reduced Sulfur (TRS)	2.22	
VOC (as Hexane)	235	AP-42 Table 2.4-2 footnote

NorthEast Maryland Waste Disposal Authority - Oaks Landfill

Reporting Year: 2018

Summary of LFG Flow Data and Operating Parameters				
Parameter	Units	Flare System	CAT Engine	JEN Engine
Site-specific CH4 Content	%	42.7%	42.7%	42.7%
Site-specific CO2 Content	%	33.2%	33.2%	33.2%
Site-specific LFG Heat Content	Btu/scf of LFG	426.9	426.9	426.9
Site-specific LFG Flow to Device	MMscf/yr	19.95	356.29	183.54
CH4 Flow to Device	MMscf/yr	8.52	152.08	78.35
Days per Year of Operation	Days/Yr	41.76	307.50	350.58
Hours per Year of Operation	Hrs/Yr	1002.16	7380.00	8414.00
LFG Flow to Device, Apr-Sep	MMscf	15.69	173.28	89.26
CH4 Flow to Device, Apr-Sep	MMscf	6.29	71.04	36.60
Days of Operation, Apr-Sep	Days	31.16	146.46	172.00

Sample Calculations:

1. Site-specific LFG Heat Content

Standard CH4 heat content = 1000 Btu/scf

LFG Heat Content (Btu/scf) = CH4 Content of LFG (%) * CH4 Heat Content (Btu/scf)

2. CH4 Flow to Device

CH4 Flow to Device (MMScf) = CH4 Content (%) * LFG Flow to Device (MMscf)

3. Normalized LFG Flow to Device (adjusted to 50% CH4)

Normalized LFG Flow to Device (MMscf) = Site-specific LFG flow (MMscf) * Site-specific CH4 Content (%) / Standard CH4 Content (50%)

Equipment	Pollutant	Factor	Units	Reference
Flare	NOx	39	lb/MMdscf CH4	AP-42 Table 2.4-4 (10/08)
Flare	CO	46	lb/MMdscf CH4	AP-42 Table 2.4-4 (10/08)
Flare	VOC	51.71	lb/MMdscf LFG	Concentration in LFG; AP-42 Section 2.4, equations 3 and 4
Flare	TPM	15	lb/MMdscf CH4	AP-42 Table 2.4-4 (10/08)
Flare	TPM10	15	lb/MMdscf CH4	AP-42 Table 2.4-4 (10/08)
Flare	TPM2.5	15	lb/MMdscf CH4	AP-42 Table 2.4-4 (10/08)
Flare	FPM	3.75	lb/MMdscf CH4	Historical calculations; FPM/TPM = 0.25, AP-42 Table 1.4-2
Flare	FPM10	3.75	lb/MMdscf CH4	Historical calculations; FPM/TPM = 0.25, AP-42 Table 1.4-2
Flare	FPM2.5	3.75	lb/MMdscf CH4	Historical calculations; FPM/TPM = 0.25, AP-42 Table 1.4-2
Flare	CPM	11.25	lb/MMdscf CH4	Historical calculations; CPM/TPM = 0.75, AP-42 Table 1.4-2
Flare	SO2	0.36	lb/MMdscf LFG	TRS concentration in LFG; AP-42 Section 2.4, equations 3 and 4
Flare	CH4	Mass Balance		
Flare	CO2	Mass Balance		
Flare	N2O	6.30E-04	kg/MMBtu	40 CFR 98 Table C-2
Caterpillar Engine	NOx	0.28	g/BHP-hr	Stack test data 5/30/2018 (p. 10)
Caterpillar Engine	CO	2.04	g/BHP-hr	Stack test data 5/30/2018 (p. 10)
Caterpillar Engine	VOC	0.0021	g/BHP-hr	Stack test data 5/30/2018 (p. 10)
Caterpillar Engine	TPM	15	lb/MMdscf CH4	AP-42 Table 2.4-4 (10/08)
Caterpillar Engine	TPM10	15	lb/MMdscf CH4	AP-42 Table 2.4-4 (10/08)
Caterpillar Engine	TPM2.5	15	lb/MMdscf CH4	AP-42 Table 2.4-4 (10/08)
Caterpillar Engine	FPM	3.75	lb/MMdscf CH4	Historical calculations; FPM/TPM = 0.25, AP-42 Table 1.4-2
Caterpillar Engine	FPM10	3.75	lb/MMdscf CH4	Historical calculations; FPM/TPM = 0.25, AP-42 Table 1.4-2
Caterpillar Engine	FPM2.5	3.75	lb/MMdscf CH4	Historical calculations; FPM/TPM = 0.25, AP-42 Table 1.4-2
Caterpillar Engine	CPM	11.25	lb/MMdscf CH4	Historical calculations; CPM/TPM = 0.75, AP-42 Table 1.4-2
Caterpillar Engine	SO2	0.36	lb/MMdscf LFG	TRS concentration in LFG; AP-42 Section 2.4, equations 3 and 4
Caterpillar Engine	CH4	Mass Balance		
Caterpillar Engine	CO2	Mass Balance		
Caterpillar Engine	N2O	6.30E-04	kg/MMBtu	40 CFR 98 Table C-2
GE Jenbacher Engine	NOx	0.73	g/BHP-hr	Stack test data 5/30/2018 (p. 11)
GE Jenbacher Engine	CO	3.01	g/BHP-hr	Stack test data 5/30/2018 (p. 11)
GE Jenbacher Engine	VOC	0.0116	g/BHP-hr	Stack test data 5/30/2018 (p. 11)
GE Jenbacher Engine	TPM	15	lb/MMdscf CH4	AP-42 Table 2.4-4 (10/08)
GE Jenbacher Engine	TPM10	15	lb/MMdscf CH4	AP-42 Table 2.4-4 (10/08)
GE Jenbacher Engine	TPM2.5	15	lb/MMdscf CH4	AP-42 Table 2.4-4 (10/08)
GE Jenbacher Engine	FPM	3.75	lb/MMdscf CH4	Historical calculations; FPM/TPM = 0.25, AP-42 Table 1.4-2
GE Jenbacher Engine	FPM10	3.75	lb/MMdscf CH4	Historical calculations; FPM/TPM = 0.25, AP-42 Table 1.4-2
GE Jenbacher Engine	FPM2.5	3.75	lb/MMdscf CH4	Historical calculations; FPM/TPM = 0.25, AP-42 Table 1.4-2
GE Jenbacher Engine	CPM	11.25	lb/MMdscf CH4	Historical calculations; CPM/TPM = 0.75, AP-42 Table 1.4-2
GE Jenbacher Engine	SO2	0.36	lb/MMdscf LFG	TRS concentration in LFG; AP-42 Section 2.4, equations 3 and 4
GE Jenbacher Engine	CH4	Mass Balance		
GE Jenbacher Engine	CO2	Mass Balance		
GE Jenbacher Engine	N2O	6.30E-04	kg/MMBtu	40 CFR 98 Table C-2

Calculation Constants	
298	deg K
32	g/gmol
64	g/gmol
8.21E-05	m^3 - atm/gmol - K
35.31	ft^3/m^3
453.6	g/lb
86.18	g/gmol
	MW of VOC as Hexane (AP-42 Table 2.4-2)

Criteria Pollutant Emissions Summary
NorthEast Maryland Waste Disposal Authority - Oaks Landfill
Reporting Year: 2018

Criteria Pollutant Emissions Summary
Northern Maryland Waste Disposal Authority - Oaks Landfill
Reporting Year: 2018

Criteria Pollutant Emissions Summary
Northern Maryland Waste Disposal Authority - Oaks Landfill
Reporting Year: 2018

Device: **Landfill Gas Flare System**

Pollutant	Actual Emissions TPY	Emissions lb/day	Emissions Basis	TOSD*
NOx	0.17	7.95	AP-42	7.87
CO	0.20	9.38	AP-42	-
VOC	0.01	0.49	AP-42, manuf control eff.	0.21
TPM	0.06	3.06	AP-42	-
TPM10	0.06	3.06	AP-42	-
TPM2.5	0.06	3.06	AP-42	-
FPM	0.02	0.76	Historical calcs, AP-42	-
FPM10	0.02	0.76	Historical calcs, AP-42	-
FPM2.5	0.02	0.76	Historical calcs, AP-42	-
CPM	0.05	2.29	Historical calcs, AP-42	-
SO2	0.00	0.17	LFG test data, AP-42	-

Device: **Caterpillar Engine**

Pollutant	Actual Emissions TPY	Emissions lb/day	Emissions Basis	TOSD*
NOx	4.48	29.15	Test data	24.26
CO	28.24	183.67	Test data	-
VOC	0.03	0.19	Test data	0.18
TPM	1.14	7.42	AP-42	-
TPM10	1.14	7.42	AP-42	-
TPM2.5	1.14	7.42	AP-42	-
FPM	0.29	1.85	Historical calcs, AP-42	-
FPM10	0.29	1.85	Historical calcs, AP-42	-
FPM2.5	0.29	1.85	Historical calcs, AP-42	-
CPM	0.86	5.56	Historical calcs, AP-42	-
SO2	0.06	0.42	LFG test data, AP-42	-

Device: **GE Jenbacher Engine**

Pollutant	Actual Emissions TPY	Emissions lb/day	Emissions Basis	TOSD*
NOx	6.41	36.57	Test data	35.46
CO	26.25	149.75	Test data	-
VOC	0.10	0.58	Test data	0.56
TPM	0.59	3.35	AP-42	-
TPM10	0.59	3.35	AP-42	-
TPM2.5	0.59	3.35	AP-42	-
FPM	0.15	0.84	Historical calcs, AP-42	-
FPM10	0.15	0.84	Historical calcs, AP-42	-
FPM2.5	0.15	0.84	Historical calcs, AP-42	-
CPM	0.44	2.51	Historical calcs, AP-42	-
SO2	0.03	0.19	LFG test data, AP-42	-

* TOSD = Typical Ozone Season Day (Apr-Sep), applies to NOx and VOC only.

* TOSD = Typical Ozone Season Day (Apr-Sep), applies to NOx and VOC only.

* TOSD = Typical Ozone Season Day (Apr-Sep), applies to NOx and VOC only.

Toxic Air Pollutant Emissions
 NorthEast Maryland Waste Disposal Authority - Oaks Landfill
 Reporting Year:
 2018

LFG Flow to Flares = 19.95 MMscf/yr
 Flare Operating Days = 41.76 days/yr
 Flare Operating Hours = 1002.16 hrs/yr

LFG Flow to CAT Engine = 356.29 MMscf/yr
 CAT Engine Operating Days = 307.50 days/yr
 CAT Engine Operating Hours = 7380.00 hrs/yr

LFG Flow to JEN Engine = 183.54 MMscf/yr
 JEN Engine Operating Days = 350.58 days/yr
 JEN Engine Operating Hours = 8414.00 hrs/yr

Pollutant	Molecular Weight (g/mol)	Concentration (ppmv)	Flare Pollutant Inflow (lb/yr)	Flare Destruction Efficiency	Flare Emissions			CAT Engine Pollutant Inflow (lb/yr)	CAT Engine Destruction Efficiency	CAT Engine Emissions (lb/day) (lb/hr) (ton/yr)			Pollutant Inflow (lb/yr)	JEN Engine Destruction Efficiency	JEN Engine Emissions (lb/day) (lb/hr) (ton/yr)			Facility Total Emissions (lb/day) (lb/hr) (ton/yr)				
					(lb/day)	(lb/hr)	(ton/yr)			(lb/day)	(lb/hr)	(ton/yr)			(lb/day)	(lb/hr)	(ton/yr)	(lb/day)	(lb/hr)	(ton/yr)		
1,1,1-Trichloroethane (methyl chloroform)	133.4	0.04	0.3	98.0%	0.00	0	0	4.9	97.2%	0.00	0	0	2.5	97.2%	0.00	0	0	0.00	0	0		
1,1,2,2-Tetrachloroethane	167.85	0.06	0.5	98.0%	0.00	0.0	0	9.2	97.2%	0.00	0	0	4.7	97.2%	0.00	0	0	0.00	0	0		
1,1,2,3,4,4-Hexachloro-1,3-butadiene (Hexachlorobutadiene)	260.76	0.06	0.8	98.0%	0.00	0.000	0.00	14.2	97.2%	0.00	0.000	0.00	7.3	97.2%	0.00	0.000	0.00	0.00	0.000	0.00		
1,1,2-Trichloroethane	133.4	0.06	0.4	98.0%	0.00	0.0	0	7.3	97.2%	0.00	0	0	3.7	97.2%	0.00	0	0	0.00	0	0		
1,1-Dichloroethane (ethylidene dichloride)	98.96	1.18	5.9	98.0%	0.00	0	0	106.2	97.2%	0.01	0	0	54.7	97.2%	0.00	0	0	0.02	0	0		
1,1-Dichloroethane (vinylidene chloride)	96.94	0.06	0.3	98.0%	0.00	0.0	0	5.3	97.2%	0.00	0.000	0.00	2.7	97.2%	0.00	0	0	0.00	0	0		
1,2,4-Trichlorobenzene	181.45	0.06	0.6	98.0%	0.00	0.0	0	9.9	97.2%	0.00	0.000	0.00	5.1	97.2%	0.00	0	0	0.00	0	0		
1,2-Dichloroethane (ethylene dichloride)	98.96	0.06	0.3	98.0%	0.00	0.0	0	5.4	97.2%	0.00	0.000	0.00	2.8	97.2%	0.00	0	0	0.00	0	0.00		
1,2-Dichloropropane (propylene dichloride)	112.99	0.06	0.3	98.0%	0.00	0	0	6.2	97.2%	0.00	0	0	3.2	97.2%	0.00	0	0	0.00	0	0		
1,3-Butadiene (vinyl ethylene)	54.09	0.06	0.2	98.0%	0.00	0.000	0.00	3.0	97.2%	0.00	0.000	0.000	1.5	97.2%	0.00	0.000	0.000	0.00	0.000	0.000		
1,3-Dichloropropene	110.97	0.06	0.3	98.0%	0.00	0.000	0.00	6.1	97.2%	0.00	0.000	0.000	3.1	97.2%	0.00	0.000	0.000	0.00	0.000	0.000		
1,4-Dichlorobutene	147.02	0.04	0.5	98.0%	0.00	0.000	0.00	5.3	97.2%	0.00	0	0	2.8	97.2%	0.00	0	0	0.00	0	0.00		
1,4-Dioxane (1,4-dieethylene dioxide)	88.11	0.06	0.3	98.0%	0.00	0	0	4.8	97.2%	0.00	0	0	2.5	97.2%	0.00	0	0	0.00	0	0.00		
2,2,4,4-Trimethylbenzene	114.23	0.06	0.3	98.0%	0.00	0.0	0	6.2	97.2%	0.00	0	0	3.2	97.2%	0.00	0	0	0.00	0	0		
2-Butanone (methyl ethyl ketone)	72.11	1.27	4.7	98.0%	0.00	0	0	83.3	97.2%	0.01	0	0	42.9	97.2%	0.00	0	0	0.01	0	0		
4-Methyl-2-pentanone (Methyl isobutyl ketone)	100.16	0.06	0.3	98.0%	0.00	0	0	5.5	97.2%	0.00	0	0	2.8	97.2%	0.00	0	0	0.00	0	0		
Acrylonitrile *	53.06	6.33	17.1	98.0%	0.01	0.000	0.00	305.4	97.2%	0.03	0.000	0.000	157.3	97.2%	0.01	0.000	0.000	0.05	0.00	0.00		
Allyl chloride (3-Chloro-1-propene)	76.52	0.06	0.2	98.0%	0.00	0.000	0.00	4.2	97.2%	0.00	0.000	0.000	2.2	97.2%	0.00	0.000	0.000	0.00	0.000	0.000		
Benzene	78.11	0.272	1.1	98.0%	0.00	0.000	0.00	19.3	97.2%	0.00	0.000	0.000	10.0	97.2%	0.00	0.000	0.000	0.00	0.000	0.000		
Benzyl chloride	126.58	0.06	0.4	98.0%	0.00	0.000	0.00	6.9	97.2%	0.00	0.000	0.000	3.6	97.2%	0.00	0.000	0.000	0.00	0.000	0.000		
Bromomethane (Methyl bromide)	94.94	0.06	0.3	98.0%	0.00	0.000	0.00	5.2	97.2%	0.00	0.000	0.000	2.7	97.2%	0.00	0.000	0.000	0.00	0.000	0.000		
Bromoethene (Vinyl bromide)	106.95	0.06	0.3	98.0%	0.00	0.000	0	5.8	97.2%	0.00	0.000	0	3.0	97.2%	0.00	0.000	0	0.00	0	0.000		
Carbon disulfide	76.14	0.06	0.2	98.0%	0.00	0.000	0	4.2	97.2%	0.00	0.000	0	2.1	97.2%	0.00	0	0	0.00	0	0.000		
Carbon tetrachloride	153.82	0.04	0.3	98.0%	0.00	0.000	0.00	5.6	97.2%	0.00	0.000	0.000	2.9	97.2%	0.00	0.000	0.000	0.00	0.000	0.000		
Carbonyl sulfide (Carbon oxysulfide) *	60.08	0.49	1.5	98.0%	0.00	0.0	0	26.8	97.2%	0.00	0	0	13.8	97.2%	0.00	0	0	0.00	0	0.000		
Chlorine *	35.45	42	75.8	n/a	n/a	n/a	n/a	1353.7	n/a	n/a	n/a	n/a	697.4	n/a	n/a	n/a	n/a	n/a	n/a	n/a		
Chlorobenzene	112.56	0.06	0.3	98.0%	0.00	0.0	0	6.1	97.2%	0.00	0.000	0.000	3.2	97.2%	0.00	0	0	0.00	0	0.000		
Chloroethane (Ethyl chloride)	64.51	0.208	0.7	98.0%	0.00	0.000	0.00	12.2	97.2%	0.00	0.000	0.000	6.3	97.2%	0.00	0.000	0.000	0.00	0.000	0.000		
Chloromethane (Methyl chloride)	50.49	0.06	0.2	98.0%	0.00	0.0	0	2.8	97.2%	0.00	0.000	0.000	1.4	97.2%	0.00	0.000	0.000	0.00	0.000	0.000		
Dichloromethane (Methylene chloride)	84.93	0.115	0.5	98.0%	0.00	0	0	8.9	97.2%	0.00	0	0	4.6	97.2%	0.00	0	0	0.00	0	0.000		
Ethylbenzene	106.17	0.868	4.7	98.0%	0.00	0	0	83.8	97.2%	0.01	0	0	43.2	97.2%	0.00	0	0	0.01	0	0		
Hexachlorobutadiene	260.76	0.06	0.8	98.0%	0.00	0.000	0.00	14.2	97.2%	0.00	0.000	0.000	7.3	97.2%	0.00	0.000	0.000	0.00	0.000	0.000		
n-Hexane	86.18	0.78	3.4	98.0%	0.00	0	0	61.1	97.2%	0.01	0	0	31.5	97.2%	0.00	0	0	0.01	0	0		
Hydrochloric Acid *	36.46	42	78.0	0.00	1.87	0.1	0.0	1392.3	0.0%	4.53	0.2	0.7	717.3	0.0%	2.05	0.1	0.4	8.44	0.4	1.1		
Mercury (Total) *	200.59	0.000292	0.0	0.00	0.000	0.000	0.000	0.1	0.0%	0.000	0.00000	0.000	0.0	0.0%	0.00000	0.000	0.00000	0.000	0.00000	0.000		
Methyl tert-butyl ether (MTBE)	88.15	0.084	0.4	98.0%	0.00	0	0	6.7	97.2%	0.00	0	0	3.5	97.2%	0.00	0	0	0.00	0	0		
Styrene (Vinylbenzene)	104.15	0.06	0.3	98.0%	0.00	0	0	5.7	97.2%	0.00	0	0	2.9	97.2%	0.00	0	0	0.00	0	0		
Tetrachloroethylene (Perchloroethylene)	165.83	0.265	2.2	98.0%	0.00	0	0	40.0	97.2%	0.00	0	0	20.6	97.2%	0.00	0	0	0.01	0	0		
Toluene (Methyl benzene)	92.14	4.16	19.5	98.0%	0.01	0	0	348.5	97.2%	0.03	0	0	179.5	97.2%	0.01	0	0	0.06	0	0		
Tribromomethane (Bromform)	252.73	0.04	0.5	98.0%	0.00	0.000	0.00	9.2	97.2%	0.00	0.000	0.000	4.7	97.2%	0.00	0.000	0.000	0.00	0.000	0.000		
Trichloroethylene (Trichloroethene)	131.39	0.158	1.1	98.0%	0.00	0	0	18.9	97.2%	0.00	0	0	9.7	97.2%	0.00	0	0	0.00	0	0		
Trichloroethylene (Chloroform)	119.38	0.04	0.2	98.0%	0.00	0.0	0.000	4.3	97.2%	0.00	0.000	0.000	2.2	97.2%	0.00	0	0.000	0.000	0.000	0.000		
Vinyl acetate	86.09	0.06	0.3	98.0%	0.00	0.0	0	4.7	97.2%	0.00	0.000	0.000	2.4	97.2%	0.00	0	0	0.00	0	0.000		
Vinyl chloride (Chloroethene)	62.5	1.78	5.7	98.0%	0.00	0.0	0.000	101.2	97.2%	0.01	0.000	0.000	52.1	97.2%	0.00	0.000	0.000	0.02	0.00	0.000		
Xylenes (o-, m-, p-, mixtures)	106.17	0.39	2.1	98.0%	0.00	0	0	37.6	97.2%	0.00	0	0	19.4	97.2%	0.00	0	0	0.01	0	0		
Total Air Toxics					1.91	0.10	0.00					4.66	0.20	0.70			2.10	0.10	0.40	8.67	0.40	1.10

* Laboratory data not available; default values from AP-42 Section 2.4 were used.

Pollutant Inflow (lb/yr) = Conc (ppmv)/10⁶ * MW (g/mol) / 8.21E-05

(atm-m³/g/mol-K) / 298 K / 35.31 (ft³/m³) / 453.6 (g/lb) * 10⁶ (scf/MMscf)

* LFG flow (MMscf/yr)

Greenhouse Gas Emissions

NorthEast Maryland Waste Disposal Authority - Oaks Landfill

Reporting Year: 2018

Calculation Constants and Input Parameters

Description	Value	Units
Site-specific CO2 Content of LFG	33.2%	%
Site-specific CH4 Content of LFG	42.7%	%
Site-specific LFG heat content	426.9	Btu/scf
Default temperature of LFG, 25 deg C, AP-42 Section 2.4	298	deg K
Ideal gas constant	8.21E-05	(m^3 - atm) / (gmol - K)
MW of CO2	44.01	g/gmol
MW of CH4	16.044	g/gmol
Default N2O factor, 40 CFR 98 Table C-2	6.30E-04	kg/MMBtu

Emissions Parameter	Units	Flares	CAT Engine	JEN Engine
LFG Flow to Device	MMscf/yr	19.95	356.29	183.54
Days of Operation	Days/Yr	41.76	307.50	350.58
Hours of Operation	Hrs/Yr	1002.16	7380.00	8414.00
Destruction Efficiency	%	98.0%	97.2%	97.2%
Volume of CO2 Emissions	MMscf/yr	15.14	270.36	139.28
Mass of CO2 Emissions	TPY	850.6	15191.3	7825.8
	lb/day	40741.8	98805.3	44644.6
	lb/hr	1697.6	4116.9	1860.2
Volume of CH4 Emissions	MMscf/yr	0.170	4.258	2.194
Mass of CH4 Emissions	TPY	3.5	87.2	44.9
	lb/day	167.1	567.3	256.3
	lb/hr	7.0	23.6	10.7
Mass of N2O Emissions	TPY	0.01	0.11	0.05
	lb/day	0.28	0.69	0.31
	lb/hr	0.01	0.03	0.01

Calculation Notes:

1. CO2 Emissions

- Burning LFG produces CO2, and LFG also contains CO2.
- The CO2 emissions from burning LFG are calculated using the site-specific CH4 and CO2 contents of the LFG and assuming that all CH4 in the LFG is burned. 1 mole of CH4 produces 1 mole of CO2.

Sample Calculations for CO2 :

- Volume of Emissions (MMscf/yr) = LFG flow to device (MMscf/yr) * (LFG CO2 content % + LFG CH4 content %)
- Mass of Emissions (lb/yr) = Volume Emissions (MMscf/yr) * 10^6 (scf/MMscf) / 35.31 (cf/m3) * MW (g/gmol) / Gas Constant (atm-m3/gmol-K) / LFG Temperature (K) / 453.6 (g/lb)

2. CH4 Emissions

- LFG contains CH4. Uncombusted CH4 is released from the flares and engines.

Sample Calculations for CH4:

- Volume of Emissions (MMscf/yr) = LFG flow to device (MMscf/yr) * LFG CH4 content (%) * (1-Destruction Efficiency %)
- Mass of Emissions (lb/yr) = Volume Emissions (MMscf/yr) * 10^6 (scf/MMscf) / 35.31 (cf/m3) * MW (g/gmol) / Gas Constant (atm-m3/gmol-K) / LFG Temperature (K) / 453.6 (g/lb)

3. N2O Emissions

N2O Emissions (ton/yr) = LFG flow to device (MMscf/yr) * LFG Heat content (Btu/scf) * N2O factor (kg/MMBtu) * 2.2 (lb/kg) / 2000 (lb/ton)

Monthly Rolling NOx Emissions

NorthEast Maryland Waste Disposal Authority - Oaks Landfill

Reporting Year: 2018

Links to Input Data tab

Month	Emissions Factor ¹ (g/HP-hr)		Power Output (BHP-hr)		Flare Flow (MMscf)	Methane (%)	NOx Emissions (tons)			Total Monthly NOx (tons)	Total 12-Mo. Rolling Summary (tons)
	CAT Engine	JEN Engine	CAT Engine	JEN Engine			CAT Engine ²	JEN Engine ²	Flare ³		
Jan-18	0.39	0.74	1,219,428	705,661	0.18	46.0%	0.52	0.58	0.00	1.10	11.61
Feb-18	0.39	0.74	1,218,494	635,058	0.01	46.1%	0.52	0.52	0.00	1.04	11.65
Mar-18	0.39	0.74	1,133,488	660,575	0.67	41.3%	0.48	0.54	0.01	1.03	11.31
Apr-18	0.39	0.74	988,387	673,557	0.02	40.7%	0.42	0.55	0.00	0.97	11.34
May-18	0.39	0.74	619,767	668,231	7.99	39.8%	0.26	0.55	0.06	0.87	11.33
Jun-18	0.28	0.73	798,042	514,140	2.88	38.8%	0.25	0.41	0.02	0.68	11.03
Jul-18	0.28	0.73	1,125,159	620,640	4.40	41.3%	0.35	0.50	0.04	0.88	11.19
Aug-18	0.28	0.73	1,084,849	655,160	0.14	42.4%	0.33	0.53	0.00	0.86	11.05
Sep-18	0.28	0.73	1,140,112	658,364	0.26	42.3%	0.35	0.53	0.00	0.88	10.93
Oct-18	0.28	0.73	1,190,267	692,161	0.27	43.4%	0.37	0.56	0.00	0.93	10.87
Nov-18	0.28	0.73	742,631	682,268	3.05	44.9%	0.23	0.55	0.03	0.80	11.18
Dec-18	0.28	0.73	1,297,584	745,547	0.09	45.2%	0.40	0.60	0.00	1.00	11.05
Total Emissions for Reporting Year							4.48	6.41	0.16		

1. Engine Emission Factors from "Compliance Emissions Test Report" as follows:

NOx Emissions Factor (g/BHP-hr)

Test Date	CAT Engine	JEN Engine
12/18/2012	0.37	1.04
12/3/2013	0.64	0.78
2/16/2016-2/17/20	0.58	0.74
4/17/2017	0.39	0.74
5/30/2018	0.28	0.73

2. Engine Emissions = Emissions Factor (g/BHP-hr) * Power Output (BHP-hr) * (1 lb/453.6 g) * (1 ton/2000 lbs)

3. Flare Emissions = Flare Flow (MMscf) * Methane % * Flare NOx Factor (lb/MMscf CH4) * (1 ton/2000 lbs)

Flare NOx Factor = 39 lb/MMdscf CH4 AP-42 Table 2.4-4 (10/08)