

Inspection Checklist – Fire Code Compliance

The following checklist includes the most common items the Fire Inspector will look for in your space. It is not all inclusive and is meant to be a guide to assist owners and inspectors.

General

- | | | | |
|--|------------------------------|-----------------------------|------------------------------|
| 1. Building address numbers visible and at least 6" in height? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 2. Are the Knox box keys correct? 2 sets, Color Coded? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 3. Combustible storage is not excessive for the space? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 4. The space has the appropriate U&O? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |

Egress

- | | | | |
|---|------------------------------|-----------------------------|------------------------------|
| 1. Are exits, exit access, and exit discharge are clear and unobstructed? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | |
| 2. Is aisle width adequate? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 3. Is there adequate emergency lighting? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 4. No storage in or under stairs? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |

Fire Protection Systems

- | | | | |
|--|------------------------------|-----------------------------|------------------------------|
| 1. Are pull stations readily accessible? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 2. Sprinkler heads are unobstructed and undamaged? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 3. Fire extinguishers are located appropriately and inspected monthly? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 4. Cooking appliances are protected (hood and ducts, suppression)? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 5. Smoke alarms are hardwired, interconnected with battery back-up? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 6. Fire alarm annunciator panel is free of alarms and troubles? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 7. Sprinkler valves are open and system is in working order? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |

Building Utilities / Other

- | | | | |
|--|------------------------------|-----------------------------|------------------------------|
| 1. Door signs to Sprinkler and FACP room(s) | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 2. Utility Access – 36" clearance to and around utilities | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 3. Fire department connection is visible and accessible? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 4. Fire doors close and latch? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 5. Fire resistive barriers and opening protectives are free of damage? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 6. Escape windows are accessible and operable? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |

Endorsements ☐ n/a

- | | | | |
|--|------------------------------|-----------------------------|------------------------------|
| 1. Documents up to date and submitted with permit application to ePlans? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 2. Un-sprinkled high-rises have exterior signage? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 3. Multifamily apartment buildings have approved emergency safety plans? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |
| 4. Building/space has an active valid FCC permit? | <input type="checkbox"/> Yes | <input type="checkbox"/> No | <input type="checkbox"/> n/a |