



DEPARTMENT OF PERMITTING SERVICES

Marc Elrich
County Executive

Rabbiah Sabbakhan
Director

June 1, 2023

Mr. Dean Packard, PE
Packard and Associates, LLC
16220 Frederick Road, Suite 300
Gaithersburg, Maryland

Re: **COMBINED STORMWATER MANAGEMENT
CONCEPT/SITE DEVELOPMENT
STORMWATER MANAGEMENT PLAN** for
Brookstone Senior Living
Preliminary Plan #: None Provided
Conditional Use Site Plan
SM File #: 288605
Tract Size: 255,571 sf/5.87 Acres
Zone RMH-200
Total Concept Area: 195,261 sf/4.48 Acres
Lots/Block: 27/B
Watershed: Little Paint Branch/Class I
Type of Development: New Development

Dear Mr. Packard:

Based on a review by the Department of Permitting Services Review Staff, the stormwater management concept for the above-mentioned site is **acceptable**. The plan proposes to meet required stormwater management goals via the use of micro-bioretenion.

The following items will need to be addressed during the detailed sediment control/stormwater management plan stage:

1. A detailed review of the stormwater management computations will occur at the time of detailed plan review.
2. An engineered sediment control plan must be submitted for this development.
3. All filtration media for manufactured best management practices, whether for new development or redevelopment, must consist of MDE approved material.
4. Landscaping in areas located within the stormwater management easement which are shown on the approved Landscape Plan as part of the approved Site Plan are illustrative purpose only and may be changed at the time of detailed plan review of the Sediment Control/Storm Water Management plans by the Montgomery County Department of Permitting Services, Water Resources Section.
5. This approval is dependent on the proposed storm drain outfall to the unnamed tributary of the Little Paint Branch. If the storm drain outfall is redirected to DEP Asset #23148, then a revision to the approved concept will be required.



2425 Reedie Drive, 7th Floor, Wheaton, Maryland 20902 | 240-777-0311
www.montgomerycountymd.gov/permittingervices

Exhibit 30
OZAH Case No: CU 23-12

Mr. Dean Packard, PE
June 1, 2023
Page 2 of 2

6. A flood plain district permit will be required for any disturbance in the flood plain and flood plain buffer at the final design stage.

This list may not be all-inclusive and may change based on available information at the time.

Payment of a stormwater management contribution in accordance with Section 2 of the Stormwater Management Regulation 4-90 **is not required**.

This letter must appear on the sediment control/stormwater management plan at its initial submittal. The concept approval is based on all stormwater management structures being located outside of the Public Utility Easement, the Public Improvement Easement, and the Public Right of Way unless specifically approved on the concept plan. Any divergence from the information provided to this office; or additional information received during the development process; or a change in an applicable Executive Regulation may constitute grounds to rescind or amend any approval actions taken, and to reevaluate the site for additional or amended stormwater management requirements. If there are subsequent additions or modifications to the development, a separate concept request shall be required.

If you have any questions regarding these actions, please feel free to contact Sherryl Mitchell at 240-777-5206 or sherryl.mitchell@montgomerycountymd.gov.

Sincerely,

Mark Etheridge

Mark Etheridge, Manager
Water Resources Section
Division of Land Development Services

cc: Neil Braunstein
SM File # 288605

ESD: Required/Provided 18,427 cf / 18,437 cf
PE: Target/Achieved: 1.80"/1.80"
STRUCTURAL: N/A cf
WAIVED: N/A cf.