



DEPARTMENT OF PERMITTING SERVICES

Marc Elrich
County Executive

Rabbiah Sabbakhan
Director

October 10, 2023

Mr. Mike Norton
Norton Land Design, LLC
5146 Dorsey Hall Dr, 2nd Floor
Ellicott City, MD 21042

Re: **COMBINED STORMWATER MANAGEMENT
CONCEPT/SITE DEVELOPMENT
STORMWATER MANAGEMENT PLAN** for
TCG Barnesville
Preliminary Plan #: NA
SM File #: 289719
Tract Size/Zone: 40.98 ac. / AR
Total Concept Area: 0.37 ac.
Lots/Block: NA
Parcel(s): 653
Watershed: Little Monocacy

Dear Mr. Norton:

Based on a review by the Department of Permitting Services Review Staff, the stormwater management concept for the above-mentioned site is **acceptable**. The plan proposes to meet required stormwater management goals via the use of one (1) landscape infiltration practice.

The following items will need to be addressed during the detailed sediment control/stormwater management plan stage:

1. A detailed review of the stormwater management computations will occur at the time of detailed plan review.
2. An engineered sediment control plan must be submitted for this project.
3. All filtration media for manufactured best management practices, whether for new development or redevelopment, must consist of MDE approved material.
4. Note that a stormwater management easement will be required prior to sediment control permit issuance. The easement must be in the name of the property owner, regardless of who is applying for and obtaining permits and performing the actual work.

This list may not be all-inclusive and may change based on available information at the time.

Payment of a stormwater management contribution in accordance with Section 2 of the Stormwater Management Regulation 4-90 **is not required**.

This letter must appear on the sediment control/stormwater management plan at its initial submittal. The concept approval is based on all stormwater management structures being located



2425 Reedie Drive, 7th Floor, Wheaton, Maryland 20902 | 240-777-0311
www.montgomerycountymd.gov/permittingervices

Mr. Mike Norton
October 10, 2023
Page 2 of 2

outside of the Public Utility Easement, the Public Improvement Easement, and the Public Right of Way unless specifically approved on the concept plan. Any divergence from the information provided to this office; or additional information received during the development process; or a change in an applicable Executive Regulation may constitute grounds to rescind or amend any approval actions taken, and to reevaluate the site for additional or amended stormwater management requirements. If there are subsequent additions or modifications to the development, a separate concept request shall be required.

If you have any questions regarding these actions, please feel free to contact Pat Fitzgerald at 240-777-6362.

Sincerely,



Mark Etheridge, Manager
Water Resources Section
Division of Land Development Services

cc: Neil Braunstein
SM File # 289719

ESD: Required/Provided 522 cf / 665 cf
PE: Target/Achieved: 1.0"/1.3"
STRUCTURAL: N/A cf
WAIVED: N/A cf.